

**FACTORY OUTLET**  
 37 Bosworth Road  
 Woolgoolga NSW 2456  
**Phone: 02 6654 1888**  
 A/H: 0407 926 043  
 Fax: 02 6654 1999  
 Email: info@midnorthconcpd.com.au  
 Website: www.midnorthconcpd.com.au

**ADMINISTRATION OFFICE**  
 152 Port Wakefield Road  
 Cavan SA 5094  
 Phone: 08 8262 1042  
 Fax: 08 8260 2460  
 Email: admin@midnorthconcpd.com.au



ABN: 61 204 682 741





Licence No. SMK1568

# 3000 Litre SEPTIC TANK

Accredited Manufacture to Australian / New Zealand Standard AS/NZS 1546.1; 1998

Y12 trimmer bars, 20 bottom cover



## SECTION A-A

NOT TO SCALE

Concrete Strength	:	40 MPa
Vibration Technique	:	External Vibration
Cement	:	AS 3972
Aggregate	:	AS 2758.1
Admixtures	:	AS 1478
Steel Reinforcing	:	AS 1302, 1304, 1303
Steel Fibre	:	Min Tensile Strength 600 MPa
Top Load Test	:	To 5KN
Lifting Method	:	Lift via inlet and outlet penetrations

All dimensions subject to change without notice.